

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 673 युनिवर्सिटी 12 Dated: 30-3-2024

It is certified that an inspection team headed by Mr. Abachesh (Chemist)

(Name of Officers with designation) from U.P. Jal Nigam (Rural) Pzd. PHED

inspected the Sant. Param Doyal Hr. Sec. School, Cranchh, Firozabad

(Name & Address of the school) on 27-03-2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. LS.2148712519234845 dated 27-3-2024

of U.P. Jal Nigam (Rural) Firozabad (PHED Lab) certified that the

Sant. Param Doyal Hr. Sec. School Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year.

Abachesh
CHEMIST

Signature with Seal:

Name : SHIVAM RAJPUT

Designation : ASSISTANT ENGINEER

Name & Address of the Office / Department :

U.P. JAL NIGAM (R)
FIROZABAD

To Manager
Sant. Param Doyal Hr. Sec. School
(Name & Address of the Institution)
Cranchh, Firozabad.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Firozabad

Office of Executive Engineer, TCD, U.P Jal Nigam, Civil Line Dabrae, Firozabad. (Test Address only)

Print

Test report

Sample ID:

U2148712519234845

User Information

Name:

Komal Singh

Mobile:

9927135218

Email:

komalsharmafirozabad@gmail.com

Pin Code:

Full Address:

Village- GONCH , Gram Panchayat- GONCH, Block- NARKHI, District- Firozabad, State- Uttar Pradesh

Sample description

Source of Sample:

Sant Param Dayal H S S Gonch Kotla road Firozabad

Village:

GONCH

Gram Panchayat:

GONCH

Block:

NARKHI

District:

Firozabad

State:

Uttar Pradesh

Address:

Remarks:

Latitude:

27.222624

Longitude:

78.4282..41

Date & time of sample collection

27.03.2024 | 10:58:00 AM

Date & time of sample received in lab

27.03.2024 | 11:08:00 AM

Date & time of sample analysed

27.03.2024 | 12:10:00 PM

Date & time of report generation

27.03.2024 | 12:12:41 PM

Test results

Sl. No.	Parameter tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit in absence of alternative source(s) as per BIS 10500	Test result value	Remarks
	Chloride (as Cl)*	mg/l	250	1000	100.000	
2	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
3	Fluoride (as F)	mg/l	1	1.5	0.176	
4	Free residual Chlorine	mg/l	0.2	1	0.100	
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.350	
6	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	30.950	
7	pH*	NA	6.5-8.5	No Relaxation	7.232	
8	Sulphate (as SO ₄)*	mg/l	200	400	59.260	
9	TDS*	mg/l	500	2000	227.100	
10	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	259.700	
11	Total Hardness (As CaCO ₃)*	mg/l	200	600	170.000	
12	Turbidity*	NTU	1	5	2.745	

Note:

- 1) *indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above
- 3) The report shall not to be reproduced in full without approval of authority
- 4) This is the end of the report

***** This is an electronically generated report and does not require a signature. *****

Jal Jeevan Mission aims at potable tap water supply to every home
 Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve

Designed & Developed by NIC. Copyright © Copy NJM 2024

Print

